

GENERAL DESCRIPTION

The isolated doubler/converter DAT 4631 A is able to measure and linearise the standard thermocouples with internal or external cold junction compensation. In function of programming, the measured values are converted in a current or voltage signal. The device guarantees high accuracy and performances stability both versus time and temperature.

The programming is made by the dip-switch located in the window on the side of the enclosure. By means of dip-switches it is possible to select the input type and range and the output type without recalibrate the device.

Moreover, by Personal Computer the user can program all of the device's parameters for his own necessity; the configuration by PC allows to program the two outputs with two independent settings. For Thermocouple sensors it is possible to set the Cold Junction Compensation (CJC) as internal or external.

Moreover it is available the option of alarm for signal interruption (burn-out) that allows to set the output value as high or low out of scale .

The 1500 Vac galvanic isolation on all ways (input, outputs and power supply) eliminates the effects of all ground loops eventually existing and allows the use of the converter in heavy environmental conditions found in industrial applications.

The DAT 4631 A is in compliance with the Directive 2004/108/EC on the Electromagnetic Compatibility.

It is housed in a plastic enclosure of 12.5 mm thickness suitable for DIN rail mounting in compliance with EN-50022 and EN-50035 standards.

USER INSTRUCTIONS

The converter must be powered by a direct voltage applied to the terminals Q and R.

The analog channel measures the value from the sensor connected to the terminals the I, L and G and transmits the output measures on the terminals N and M (OUT A) and the terminals P and O (OUT B).


The input and output connections must be made as shown in the section "Connections".

It is possible to configure the converter on field by dip-switch or Personal Computer as shown in the section "Programming". The configuration by dip-switches can be made also if the device is powered (note: after the configuration the device takes some seconds to provide the right output measure).

TECHNICAL SPECIFICATIONS (Typical at 25 °C and in nominal conditions)


INPUT				OUTPUT (2 CHANNELS)				POWER SUPPLY		
Input type	Min	Max	Min.Span	Output type	Min	Max	Min Span	Power supply voltage	18 30 Vdc	
TC (CJC int./ext.)								Reverse polarity protection	60 Vdc max	
J ´	-200°C	1200°C	100°C	Current	0 mA	20 mA	4 mA	C		
K	-200°C	1300°C	100°C	Voltage	0 V	10 V	1 V	Current consumption	ΓΓ Λ	
S	0°C	1750°C	400°C				Current output	55 mA max. 25 mA max.		
R	0°C	1750°C	400°C	Output calibration			Voltage output	25 IIIA IIIax.		
В	0°C	1850°C	400°C	Current ± 7 uA Voltage ± 5 mV Burn-out values Max. output value 22 mA or 10.6 V						
E T	-200°C	1000°C	100°C				ISOLATION	1500 Vac,		
	-200°C	400°C	100°C				Among all ways			
N	-200°C	1300°C	100°C					50 Hz, 1 min		
Voltage				Min. output value 0 mA or -0.6 V			TEMPERATURE AND HUMIDITY Operative temperature -20°C +60°C Storage temperature -40°C +85°C Humidity (not condensed) 0 90 %			
mV	-100 mV		5 mV	Will. Output value 0 HIA of -0.0 V						
mV		+200 mV		Output load Resistance - Rload Current output $< 500 \Omega$						
mV	-100 mV	+800 mV	20 mV							
Input calibration (1)			Voltage output > 10 KΩ			,				
mV, TC the higher of \pm 0.1% f.s. and \pm 12 uV				Short circuit current 26 mA max.			HOUSING			
Linearity (1)									nguishing plastic	
TC ± 0.2 % f.s.			Response time (10÷ 90%) about 500 ms			Mounting DIN rail in compliance				
mV	± 0.1 % f.s.			Response time (10+ 90%) about 500 ms			with EN-50022 and			
Input impedance								EN-5003		
•							Weight about 90) g.		
,							EMC (for industrial enviro	nmonte \		
Line resistance influence (1)							Immunity	EN 61000-6-2		
TC, mV <=0.8 uV/Ohm							Emission	EN 61000-6-2 EN 61000-6-4		
Thermal drift (1)								LIIIISSIUII	LIN 0 1000-0-4	
Full scale	± 0.01%									
CJC	± 0.01%	o/°C								
CJC comp.	± 0.5°C									
(1)referred to the input	Span (differen	ce between r	nax. and min.)							

CONFIGURATION BY DIP-SWITCHES



PROGRAMMING

- 1) Open the suitable door on the side of the device.
- 2) Set the input type by the dip-switch SW1 [1..4] (see TAB.1)
- 3) Set the minimum input scale value (Zero) by the dip-switch SW1 [5..8] (see TAB.3)
- 4) Set the maximum input value (Full scale) by the dip-switch SW2 [1..6] (see TAB.3)
- 5) Set the output type by the dip-switch SW2 [7..8] (see TAB.2)




NOTE:


- It is also possible to set the dip-switches using the wizard of the configuration software following the procedure described in the section "Configuration by PC" until the step 6 and clicking on "Switch".

DIP-SWITCH CONFIGURATION TABLES

TAB.1 Input type setting



TAB.2 Output setting



TAB.3 - Input scale setting

7	Zero		Full Sca	le						
l	SW1 5 6 7 8	°C	SW2 1 2 3 4 5 6	°C	SW2 1 2 3 4 5 6	°C	SW2 1 2 3 4 5 6	°C	SW2 1 2 3 4 5 6	°C
l		Default		Default		75		225		700
l		-200		0		80		250		750
l		-100		5		85		255		800
J		-80		10		90		275		850
		-60		15		95		300		900
		-50		20		100		325		950
		-40		25		110		350		1000
		-30		30		120		375		1100
		-20		35		130		400		1200
		-10		40		140		425		1300
		0		45		150		450		1400
		10		50		160		475		1500
		20		55		170		500		1600
		50		60		180		550		1750
		100		65		190		600		1800
		150		70		200		650		1850

NOTES:

- * If the dip-switches SW1 [1..4] are all set in the position 0 ("EPROM"), the device will follow the configuration programmed by PC (input type and range, output type and range and options).
- * For all the "Tc" type selected by dip-switches, the cold junction compensation is internal.
- * If the dip-switches SW1 [5..8] are all set in the position 0 ("Default"), the device will follow the input scale programmed by PC for the input type selected by the dip-switches SW1 [1..4]
- * Eventual wrong dip-switches settings will be signalled by the blinking of the led "PWR".


CONFIGURATION BY PC

By software DATESOFT it is possible to:

- set the default programming of the device;
- program the options not available with the dip-switch; (burn-out level, CJC offset, etc...);
- read, in real time, the input and output measures;
- follow the dip-switches configuration wizard.

To configure the device follow the next steps:

- 1) Power-on the device.
- 2) Open the protection plastic label on the front of the device.
- 3) Connect the interface PRODAT to the PC (COM port) and to the device (PGRM connector).
- 4) Open DATESOFT.
- 5) Select the COM port in use.
- 6) Click on "Open COM".
- 7) Click on "Program".
- 8) Set the programming data.
- 9) Click on "Write" to send the programming data to the device.



INSTALLATION INSTRUCTIONS

The device is suitable for fitting to DIN rails in the vertical position. For optimum operation and long life follow these instructions:

When the devices are installed side by side it may be necessary to separate them by at least 5 mm in the following cases:


- If panel temperature exceeds 45°C.
- Use of high power supply value (> 27 Vdc).
- Use of output current.

Make sure that sufficient air flow is provided for the device avoiding to place raceways or other objects which could obstruct the ventilation slits. Moreover it is suggested to avoid that devices are mounted above appliances generating heat; their ideal place should be in the lower part of the panel.

Install the device in a place without vibrations.


Moreover it is suggested to avoid routing conductors near power signal cables (motors, induction ovens, inverters etc...) and to use shielded cable for connecting signals.

ISOLATION STRUCTURE




CONNECTIONS

INPUT OUTPUT



POWER SUPPLY



LIGHT SIGNALLING

LED	COLOUR	STATE	DESCRIPTION		
PWR	GREEN	ON	Device powered		
		OFF	Device not powered		
		BLINKING	Wrong dip-switches setting		

DIMENSIONS (mm)

