

Declaration of Conformity according to IECEx requirements

G.M. International S.r.l.

Declares that Associated Apparatus Models:

D5030*, D5032*

have been designed and manufactured according to the following standards:

IEC 60079-0: 2007	General requirements
IEC 60079-11: 2006	Intrinsic Safety 'i'
IEC 60079-26: 2006	Group II EPL Ga (Zone 0) Apparatus
IEC 60079-15: 2005	Type of protection 'n'
IEC 61241-11: 2005	Protection by Intrinsic Safety 'iD'
EN 61000-6-4:2007	Emission Standard Industrial Environment.
EN 61000-6-2:2005	Immunity for Industrial Environments.
EN 61326-3-1: 2008	Immunity requirements for safety-related systems.
EN 61010-1: 2001	Safety requirements for electrical equipment for measurement, control and laboratory use.

and are covered by:

IECEX BVS 10.0072 X IECEX – Certificate of Conformity
DNV-2006-OSL-ATEX-0178Q Production Quality Assessment

are suitable for installation in atmospheres with Gas and marked:

Ex nA nC [ia Ga] IIC T4 Gc

are suitable for installation in atmospheres with Dust and marked:

[Ex ia Da] IIIC

are suitable for installation in mines and marked:

[Ex ia Ma] I

Villasanta, 10 November 2010.



The image shows a handwritten signature in blue ink over a circular company seal. The seal contains the text 'G.M. INTERNATIONAL S.r.l.', 'COMPANY SEAL', and '1993'.

Glisente Landrini
Managing Director

G.M. International S.r.l.

Via S. Fiorano 70, 20058 Villasanta - MB - ITALY
Tel: +39 039 2325038 - Fax: +39 039 2325107

E-mail: info@gmintsrl.com - Web site: <http://www.gmintsrl.com/>